


8⁵ 10⁹ 17



A = Relieving arches projected from cellar onto 1st fl. plan.

1⁰ 4² 7³ 10⁷

ROOF FRAMING:

- RAFTERS ARE LAPPED AND NAILED W/ BROWHT NAILS
- RAFTERS (0³ x 0⁵ @ 2⁰ O.C) REST ON A BOARD PLATE
- UNDER TILE ROOF ARE WOOD SHINGLES
- MASONRY OF THE CHIMNEY STACK IS NOT INTEGRATED WITH REAR WALL WHICH SUGGESTS THAT THE ROOF HAS BEEN RAISED - VERY EARLY.
- BRICKS OF CHIMNEY W/IN THE ROOF ARE DIFFERENT FROM THE BRICKS ABOVE THE ROOFLINE - MORE EVID. FOR A RAISED ROOF.
- RANDOM HEADER BAND IN THE ATTIC

17 CHALMERS

- BRICK, NOT STONE

20

150 5 0 0 0 4 2