

CARMICHAEL & CO.,
Steam and Hot Water Heating,
235 WATER STREET.

Telephone,
3397 Cortlandt.

New York, March 20th, 1899.

A. D. Irving, Esq.,

Dear Sir:-

Agreeable to an appointment made on 15th inst., by letter (delivered at your office), requesting you to be prepared with a good fire etc. in Hot Water Heater ready for testing radiators, complained of. We left N. Y. City at 12.15 from 42nd St. station, Wednesday, 15th inst., with Mr. W. M. Mackay, Past President and the Secretary of the American Society of Heating & Ventilating Engineers and an authority on Hot Water Heating. We found water in your heating apparatus at a temperature of either 89 or 92 degrees Fahr. The weather outside was very disagreeable, a cold rain and sleet during most of the day and during the time we were at your house, 1.15 to 3.15 P. M. the fire under heater was in a very bad condition and we were unable with close attention to fire to get over 120 degrees Fahr. at 2.50 P.M. At an inspection made at the time we found that by a slight adjustment of valves, we commenced to get a good result in Mrs. Irving's room, and just showing results in lavatories on 1st and 2nd floors, when we were compelled to leave at 3.15 P.M. to get to office in City before closing. The temperature at that time had reached 130 degrees Fahr.

We requested your man who waited on us to keep a good fire in heater and to watch radiators and to let us know by mail as to the result. We have not heard from your house as yet.

338 WATER STREET

STEAM AND HOT WATER HEATING

CHAMBERS & CO

CARMICHAEL & CO.,
Steam and Hot Water Heating,
235 WATER STREET.

Telephone,
3397 Cortlandt.

New York, ... 189

-2-

(Monday , 20th inst.) but cannot see why apparatus should not
continue as we left it as circulation has thoroughly started
before we left house.

We would like to hear from you in regard to matter
as we have been to an expense of Fifteen (\$15.00) dollars or more
and would have been able to make a positive and complete examina-
tion, if your apparatus had been in order for testing, when we
arrived at your residence as we had requested.

Yours respectfully,

Carmichael & Co

Copy of letter

CARRMICHAEL & CO.
Steam and Hot Water Heating.
235 WATER STREET.

Telephone
3337 Central